

**BOROUGH OF SEASIDE PARK
OCEAN COUNTY, NEW JERSEY
OUR FILE: 1528-U-090**

BID #26-06 14TH AVENUE STORMWATER PUMP STATION

ADDENDUM #1

JUNE 18, 2026

The following additions to the Contract Documents will be written into any Contract for the “14TH AVENUE STORMWATER PUMP STATION” project and must be taken into account in rendering a Proposal for the work.

The following items shall be revised as follows at this time:

1. The access hatches for the pump station and valve vault have been revised to require Halliday Products Series F1R access hatches or approved equal. Plan Sheets 7 and 8 and Specification Section 333213.13 have been revised accordingly. The revised plan sheets and specification section are attached to this Addendum.
2. Four (4) explosion-proof terminal boxes, Larson Electronics Model EPJ-6-TB.8, or approved equal, shall be provided as intermediate transition points between wet well equipment conductors and the pump control panel. Plan Sheets E2.1 and E3.1 and Specification Section 333213.13 have been revised accordingly. The revised plan sheets and specification section are attached to this Addendum.
3. The stainless steel ladder extension for the valve vault has been removed from the Contract Documents. Plan Sheet 8 and Specification Section 333213.13 have been revised accordingly. The revised plan sheet and specification section are attached to this Addendum.
4. The specified air-cushioned check valve for the pump station discharge piping has been replaced with a check valve with outside lever and weight. Specification Section 333213.13 has been revised accordingly. The revised specification section is attached to this Addendum.
5. The **Bid Opening** date and time have been revised from June 24, 2026 at 10:30 AM to **June 30, 2026 at 10:30 AM**. All bids shall be submitted in accordance with the revised bid opening date and time.

All specifications and bids shall be revised accordingly.

Please complete the “Acknowledgement of Receipt of Addenda” (Page P-3), attached hereto, for receipt of this Addendum letter and include with bid documents submission.

The Acknowledgement of receipt of addenda page is a mandatory required document and failure to submit shall be deemed a fatal defect.

Posted: June 19th, 2026